



BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION

MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305)375-2901 FAX (305) 375-2908

NOTICE OF ACCEPTANCE (NOA)

Acrylux Paint Mfg. Co. Inc.
6010 Powerline Rd.
Fort Lauderdale, FL. 33309

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Acrylux Roof Mastic

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved," unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 3.
The submitted documentation was reviewed by Alex Tigera.



NOA No. : 08-1211.06
Expiration Date: 03/04/14
Approval Date: 03/04/09
Page 1 of 3

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Coatings
Material: Acrylic Elastomeric

SCOPE:

This approves **Acrylux Roof Mastic** as a roof maintenance coating manufactured by Acrylux Paint Mfg. Co. Inc., as described in this Notice of Acceptance. This product is designed to comply with the Florida building Code and the High Velocity Hurricanes Zone of the Florida Building Code.

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
PRI Construction Materials Technologies	APMC-001-02-03	ASTM D 6083 Fed Spec TT-C-555B	08/08/08

PHYSICAL PROPERTIES OF COMPONENTS

Trade names: **Acrylux Roof Mastic**

Surface Preparation: Remove all loose paint, dirt, mildew and chalk by high pressure water cleaning or other methods to obtain a sound surface.

Thickness: Apply a base coat at a minimum rate of 1.5 gal /100 ft² (10 dry mil thickness), and a top coat at a minimum rate of 1.5 gal / 100 ft² (10 dry mil thickness). Total coating thickness for roof surfaces listed below shall be 20 dry mils.

Specifications: ASTM D 6083

Description: An acrylic elastomeric coating applied to new and existing roof surfaces including:

- Spray Applied Polyurethane Foam Roofs
- Concrete Tile Roof
- Concrete
- SBS Granule Surfaced Modified Bituminous Membrane Roofs
- Smooth Surface Conventional Asphalt Built-Up Roofs

Container Size: 1, 2, 5, and 55 gallons. Note all precautions on container.

Systems Approvals: Methods of application and quantities shall comply with specific Roof Assembly, Product Control Notice of Acceptance.



LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire rating of this product.
2. Acrylux Roof Mastic shall not be applied in inclement weather conditions.
3. Acrylux Roof Mastic shall not be applied over asphaltic shingles.
4. Acrylux Roof Mastic used on Tiles shall be applied such that the headlaps are not 'filled' or 'clogged' with coating material, so as to maintain an air-permeable tile roof system.
5. The products listed herein are components of roof assemblies and are approved for use with roof assemblies that list any of the products listed herein as part of their roof assemblies Notice of Acceptance. For applications over existing single ply, smooth or granulated BUR systems. Refer applicable building code for requirements.
6. All products listed here in shall have an unannounced follow-up quality control program from an approved listing agency. Follow up test results shall be made available to BCCO upon request.
7. All approved products listed herein shall be labeled in compliance with TAS 121 and shall bear the imprint or identifiable marking of the manufacturer's name or logo and following statement:
"Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



7. Change in materials, use, or manufacture of any of the products listed herein shall be cause for termination of this Notice of Acceptance.
8. Acrylux Roof Mastic shall be applied in accordance with manufacturer's published application instructions. May not be applied on roofs with slope less than $\frac{1}{4}$:12.

END OF THIS ACCEPTANCE

